

## **Scope of Work**

Water Treatment system upgrade

for

US Embassy / Astana, Kazakhstan.

The purpose of this statement (SOW) is to establish water treatment system single trouble shoot and system upgrade in the Utility building on the US Embassy Compound in Astana. All the works shall be conducted as per manufacturers requirements/specifications as below unless otherwise specified by the Contracting Officer.

1. Provide and upgrade main control panel with the latest modules, PLC, modify schematics and attendance of Contractor's Service Engineer is required.
2. Provide and replace new softener head with electronic controller.
3. Provide and replace Chlorine Analyzer K-100 with three probes.
4. Provide all system inspection, testing and training for our local technicians in place.

The following SOW is to be performed by a qualified contractor for work required at the US Embassy Astana, Kazakhstan. The contractor's work will be conducted in July~August 2015. The client is the Government of the USA through US Embassy in Astana. The contractor shall provide all tools, equipment, materials and manpower required to perform the work specified below and shall provide all the materials meeting the performance specification requirements indicated herein.

The contractor shall prepare and submit a work plan schedule which has all operations beginning not later than July 15, 2015.

All security requirements required by the Embassy Regional Security Officer shall be followed including requirement for name checks in advance of entry onto the site, access requests and identification of vehicles and materials coming on and off the site. Information for personnel and equipment requiring access to the Embassy compound must be submitted at least 14 days prior to the date of site entry.

Working hours will be allowed between 7:00am to 7:00 pm daily, including weekends and holidays. Weekend and holiday access to the Embassy compound require 48 hour advance notification.